

13035 SW Pacific Hwy.  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 06/05/2012  
Sampled: 05/30/12 17:02  
Received: 05/31/12  
Sampled By: Bill Read  
Work Order: 2152005


**C** **Table Rock**  
**L** Attn: Beth  
**I** P.O. Box 746  
**E** Pendleton OR, 97801  
**N** Phone: (541) 276-0385  
**T**

**Project:** McNary Yacht Club  
**Project #:** N/A  
**Sampling Location:** 34099 Beachshore Dr, Hermiston OR  
**Sample Matrix:** Water

Lab Number	Sample Name						Secondary Standard*	Analysis Date/ Time
<b>2152005-04</b>	<b>120530K1a/b Men's Bathroom Sink</b>							
Wet Chemistry	<b>Method</b>	<b>Units</b>	<b>Result</b>	<b>MRL</b>	<b>EPA MCL</b>			
† Nitrate as N	SM4500-NO3 D	mg/L	9.4	0.5	10		05/31/12 12:00	

Lab Number	Sample Name	Sampled: 5/30/12 17:02		Result	Analysis Date/ Time
<b>2152005-04</b>	<b>120530K1a/b Men's Bathroom Sink</b>				
Microbiological Analysis	<b>Method</b>				
† Total Coliforms	SM 9223B (collert-18) 21st Ed.			Absent	5/31/12 13:15
† E. coli	SM 9223B (collert-18) 21st Ed.			Absent	5/31/12 13:15

ND = None detected    MRL = Minimum Reporting Limit    MCL = Maximum Contamination Limit  
† This analysis conforms to NELAC standards.

Approved by:   
Scott Dickman  
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.